Climate & Earth Systems | Jan 22, 2026 | 9 min read | By Bryan White

From Winter Storm Uri (2021) to Now: A Five-Year Audit of Texas's ERCOT Power Grid

Environment * Climate Change * Energy

Introduction: The Paradigm of the Isolated Grid

The electrical grid of Texas, managed by the Electric Reliability Council of Texas (ERCOT), represents a distinct infrastructural experiment within North America. Unlike the Eastern or Western Interconnections, which span dozens of states and provinces to share load and stabilize frequency, the Texas Interconnection stands largely alone, contiguous with state borders to avoid federal regulation under the Federal Power Act. ERCOT operates an "energy-only" market prioritizing low wholesale prices over costly reserve capacity payments.[1]

For decades, ERCOT engineered its system around summer cooling peaks, assuming the thermal fleet -- natural gas, coal, and nuclear -- would be readily available during winter.[2] In February 2021, Winter Storm Uri shattered this paradigm, exposing the interdependence between natural gas supply and electric generation alongside a systemic lack of cold-weather hardening.[3] By 2026, the grid has undergone a significant evolution from voluntary guidelines to mandatory weatherization and inspection, even as ratepayer debt, upstream fuel-supply exemptions, and rapid industrial load growth test system adequacy.[27][28][30]

Anatomy of a Collapse: Deconstructing Winter Storm Uri

The February 2021 crisis began with a planetary-scale disruption in atmospheric circulation. In early January 2021, a Sudden Stratospheric Warming (SSW) event weakened and reversed the westerly winds of the stratosphere, deforming the Stratospheric Polar Vortex and spilling cryosphere-temperature air southward.[4] A high-amplitude Rossby wave and Greenland blocking high stalled the cold air mass over Texas for up to 160 consecutive sub-freezing hours.[5] Climatological studies link such deep, stalling polar excursions to Arctic Amplification, which weakens the pole-to-equator temperature gradient.[6][7]

By February 15, 2021, heating demand surged as generation tripped offline across all fuel types.[3] At 1:51 AM, grid frequency -- synchronized at 60 Hertz (Hz) -- fell to 59.302 Hz, minutes away from automatic generator relays tripping to prevent vibrational turbine damage and triggering a weeks-long "black start" collapse.[5][8] Operators ordered 20,000 MW of forced load shedding, the largest controlled blackout in U.S. history.[5] Over 4.5 million Texans lost power, cascading into water failures, 246 confirmed deaths (with excess mortality estimates exceeding 700), and $80-130 billion in economic losses.[1][3]

The Engineering of Failure: Thermodynamics and Interdependency

Natural gas, the dispatchable backbone of ERCOT, accounted for 87% of unplanned fuel-related outages during Uri.[5] Raw natural gas emerging from subterranean

reservoirs contains water vapor and liquid condensates that freeze under sub-zero ambient temperatures. This wellhead "freeze-off" is exacerbated by the Joule-Thomson effect -- a thermodynamic principle describing how a real gas, deviating from the ideal gas law, cools rapidly as it expands across pressure-reducing valves. Without heat tracing, line heaters, or methanol injection, thousands of Permian Basin wells froze shut.[5][9]

This fuel starvation triggered a gas-electric "death spiral." Because gas processing plants and pipeline compressors require electricity, transmission utilities executing load-shed orders inadvertently de-energized unmapped gas facilities, dropping pipeline pressure and tripping more gas-fired generators offline.[5] Power plants also suffered direct cold-weather failures: frozen instrumentation sensing lines tripped coal and gas units; freezing rain iced wind turbine blades; and a frozen feedwater pump sensor tripped one reactor at the South Texas Project nuclear station, removing over 1,000 MW abruptly.[2][5]

Regulatory Overhaul and Market Redesign: Senate Bill 3 to RTC

In June 2021, Senate Bill 3 (SB 3) replaced voluntary guidelines with mandatory weatherization standards.[10] Under the Public Utility Commission of Texas (PUCT), ERCOT instituted seasonal readiness requirements -- windbreaks, thermal insulation, and heat tracing -- enforced by over 3,200 on-site inspections by 2025 and penalties up to $1,000,000 per day per violation.[10][12] SB 3 also created the Texas Electricity Supply Chain Security and Mapping Committee to map priority gas infrastructure onto utility feeder circuits, excluding them from rotating blackouts.[10][13]

However, upstream natural gas regulation under the Railroad Commission of Texas (RRC) retains controversial exemptions. While RRC Rules 3.65 and 3.66 require designated gas facilities to weatherize, operators can file Form CI-X and pay a $150 fee to opt out of priority designation -- including by asserting that a facility is "not prepared to operate during a weather emergency."[14][15]

In the wholesale market, regulators shelved the controversial Performance Credit Mechanism (PCM) in late 2024[16][17] in favor of two late-2025 upgrades: the Dispatchable Reliability Reserve Service (DRRS), compensating flexible units that start within two hours and run for four hours,[18] and Real-Time Co-optimization (RTC), which co-optimizes energy and ancillary reserves every five minutes.[17] Meanwhile, Uri's USD 9,000/MWh wholesale market defaults were socialized via House Bill 4492 securitization bonds ($2.1 billion under Subchapter N and 800 million USD under Subchapter M), embedding multi-decade surcharges onto ratepayer bills.[11][19]

Empirical Stress Tests and Emerging Risks (2022-2026)

Subsequent weather events tested ERCOT's physical hardening and growing load base. During Winter Storm Elliott (December 2022), demand peaked at 74,100 MW with zero load shed.[20] During Winter Storm Heather (January 2024), demand reached 78,138 MW; thermal units supplied ~87% of peak energy with only ~3,000 MW of forced outages, aided by gas storage withdrawals and priority-circuit mapping.[21][22][23] In January 2025, Winter Storms Cora and Enzo passed without conservation calls, supported by upgraded forecasting models with under 3% peak error.[24][25]

Table 1: Comparative Analysis of Winter Storm Impacts on ERCOT

| Feature | | Winter Storm Uri (2021) | | Winter Storm Elliott (2022) | | Winter Storm Heather (2024) |

| Duration of Freeze | | ~160 Hours (consecutive below freezing) | | ~80 Hours | | ~90 Hours |

| Peak Demand (MW) | | 69,871 (constrained by shedding) | | 74,100 | | 78,138 |

| Load Shed (MW) | | 20,000 (Max) | | 0 | | 0 |

| Generation Outages | | >50,000 MW (Weather/Fuel) | | <4,000 MW (Weather related) | | ~3,000 MW (Weather related) |

| Gas Supply Issues | | Widespread freeze-offs & power cuts | | Moderate freeze-offs | | Minor freeze-offs; storage utilized |

| Regulatory Context | | Pre-SB 3 | | SB 3 Implementation (Phase 1) | | Full Weatherization Rules in Effect |

Source Data: [5]

In summer 2026, rapid industrial load growth and statewide heat waves pushed ERCOT to new all-time demand highs: on July 22, 2026, hourly peak load reached a record 91.1 GW (6.5% above the pre-2026 record of 85.5 GW), met without emergency conservation appeals as natural gas (48%) and solar (32%) alongside battery storage carried the evening peak.[28][29] To manage surging connection requests from 75 MW+ AI data centers and industrial facilities, the PUCT approved ERCOT's "Batch Zero" large-load interconnection process (NPRR1325/PGRR145) in June 2026.[30] Still, NERC's 2025-2026 Winter Reliability Assessment warns that 24/7 AI data centers, crypto mining, and Permian Basin electrification have added roughly 20 GW of demand growth, outpacing new dispatchable thermal capacity.[26] Because solar produces zero output during winter morning peaks (5:00-9:00 AM), the grid still relies heavily on gas and battery storage,[27] while Arctic Amplification sustains the tail risk of multi-day freezes where heating demand can exceed baseline forecasts by 25%.[6][7]

Conclusion: A Fortified but Fragile System

Five years after Winter Storm Uri, the Texas grid has transitioned from laissez-faire vulnerability to mandatory weatherization, inspection, and integrated gas-electric mapping. Its performance during Winter Storms Elliott, Heather, Cora, and Enzo -- and across the record 91.1 GW peak of July 2026 -- confirms that generation assets are far better protected against severe cold and summer heat.[25][29] Yet RRC Form CI-X exemptions still obscure upstream gas reliability, and the central risk on the ERCOT island has shifted from equipment freeze-offs to resource adequacy as AI load growth and polar vortex volatility outpace dispatchable capacity additions.[14][26]

Updates... (Nov 24, 2026): Replaced HTTP 403 WAF-blocked Texas Comptroller URLs in References #1 and #11 with peer-reviewed CrossRef DOI Busby et al. (Jul 2021) in Energy Research & Social Science and ERCOT's official HB 4492 Securitization overview, aligning inline SB 3 citations to Reference #10. (Prior Nov 22, 2026 update verified publication dates across ERCOT and Texas regulatory sources and

retained the July 22, 2026 91.1 GW and Batch Zero milestones.)

References & Primary Sources

* [1] Busby, J. W., Baker, K., Bazilian, M. D., Gilbert, A. Q., Grubert, E., Rai, V., et al. (Jul 2021). Cascading risks: Understanding the 2021 winter blackout in Texas. Energy Research & Social Science, 77, 102106. -- https://doi.org/10.1016/j.erss.2021.102106

* [2] National Renewable Energy Laboratory (Jan 25, 2024). Explained: Causes of Three Recent Major Blackouts and What Is Being Done in Response. -- https://docs.nlr.gov/docs/fy24osti/87308.pdf

* [3] University of Houston, Hobby School of Public Affairs (2021). The Winter Storm of 2021. -- https://uh.edu/hobby/winter2021/storm.pdf

* [4] Lindsey, R. (Mar 5, 2021). Understanding the Arctic polar vortex. NOAA Climate.gov. -- https://www.climate.gov/news-features/understanding-climate/understanding-arctic-polar-vortex

* [5] North American Electric Reliability Corporation & Federal Energy Regulatory Commission (2021). The February 2021 Cold Weather Outages in Texas and the South Central United States. -- https://www.nerc.com/globalassets/standards/projects/2021-07/ferc-presentation-phase-2.pdf

* [6] Kretschmer, M., Coumou, D., Agel, L., Barlow, M., Tziperman, E., & Cohen, J. (Jan 1, 2018). More-Persistent Weak Stratospheric Polar Vortex States Linked to Cold Extremes. Bulletin of the American Meteorological Society, 99(1), 49-60. -- https://doi.org/10.1175/BAMS-D-16-0259.1

* [7] Cohen, J., Agel, L., Barlow, M., Garfinkel, C. I., & White, I. (Sep 3, 2021). Linking Arctic variability and change with extreme winter weather in the United States. Science, 373(6559), 1116-1121. -- https://doi.org/10.1126/science.abi9167

* [8] Kemabonta, T. (Dec 2021). Grid Resilience analysis and planning of electric power systems: The case of the 2021 Texas electricity crises caused by winter storm Uri. The Electricity Journal, 34(10), 107044. -- https://doi.org/10.1016/j.tej.2021.107044

* [9] Railroad Commission of Texas (Feb 23, 2022). RRC Report on Natural Gas Facility Weatherization Best Practices. -- https://www.rrc.texas.gov/media/ka3llgtk/rrc-best-practices-report.pdf

* [10] Texas Legislature (May 31, 2021). Senate Bill 3 (87th Legislature, Regular Session), Enrolled Text. -- https://capitol.texas.gov/tlodocs/87R/billtext/pdf/SB00003F.pdf

* [11] ERCOT (2021). HB 4492 Securitization. -- https://www.ercot.com/about/hb4492securitization

* [12] ERCOT (Feb 14, 2025). Trending Topics: Weatherization. -- https://www.ercot.com/files/docs/2025/02/14/trending_topic_weatherization.pdf

* [13] Railroad Commission of Texas (Dec 1, 2021). Rules Adopted for Critical Designation of Natural Gas Infrastructure. --

https://www.rrc.texas.gov/announcements/120121-rules-adopted-for-critical-designation-of-natural-gas-infrastructure/

* [14] Railroad Commission of Texas Public Filing (2022). Comments on Rules 3.65 and 3.107 (Form CI-X Exemptions). -- https://www.rrc.texas.gov/media/yjnpyaxs/3-65-3-107-comments-commissionshift.pdf

* [15] Baker Botts (Nov 11, 2022). Texas RRC Amends Rule on Critical Designation of Natural Gas Infrastructure. -- https://www.bakerbotts.com/thought-leadership/publications/2022/november/texas-rrc-amends-rule-on-critical-designation-of-natura

* [16] Baker Botts (Apr 25, 2023). Texas Wholesale Electricity Market Redesign. -- https://www.bakerbotts.com/thought-leadership/publications/2023/april/2022-energy-memo_texas-wholesale-electricity-market-rede

* [17] Yes Energy (May 22, 2025). New Energy Market Regulations and Trends in 2025. -- https://www.yesenergy.com/blog/new-energy-market-regulations-and-trends-in-2025

* [18] ERCOT (Dec 4, 2025). Item 6.1: NPRR1309 Dispatchable Reliability Reserve Service Ancillary Service and NOGRR283. -- https://www.ercot.com/files/docs/2025/12/04/6.1-NPRR1309-Dispatchable-Reliability-Reserve-Service-Ancillary-Service-and-NOG

* [19] ERCOT (Jun 15, 2022). ERCOT Completes Subchapter N Securitization Financing. -- https://www.ercot.com/news/release/2022-06-15-ercot-completes-subchapter-n

* [20] ERCOT (Mar 27, 2023). Winter Storm Elliott Cold Weather Operations Public Report. -- https://www.ercot.com/files/docs/2023/03/27/December-2022-Cold-Weather-Operations-Public-Report.pdf

* [21] ERCOT (Jan 31, 2024). ERCOT Monthly Report: January 2024 (Winter Storm Heather). -- https://www.ercot.com/files/docs/2024/01/31/ERCOT-Monthly-January-2024.pdf

* [22] Texas Oil & Gas Association (Jan 18, 2024). Largely Supported by Natural Gas, the Texas Electric Grid Remains Resilient Amid Winter Storm Heather. -- https://www.txoga.org/largely-supported-by-natural-gas-the-texas-electric-grid-remains-resilient-amid-winter-storm-heather/

* [23] America's Power (2024). Operation of the U.S. Power Grid During the January 2024 Storm. -- https://americaspower.org/wp-content/uploads/2024/02/2024_02_14-Jan-2024-Winter-Storms-Analysis-FINAL.pdf

* [24] ERCOT (Jan 30, 2025). Item 9.2: System Operations Update (January 2025 Winter Events). -- https://www.ercot.com/files/docs/2025/01/30/9-2-system-operations-update-revised.pdf

* [25] North American Electric Reliability Corporation (Apr 16, 2025). January 2025 Arctic Events: System Performance Review. -- https://www.nerc.com/globalassets/programs/event-analysis/25_arctic_storms_performance_review_0416.pdf

* [26] North American Electric Reliability Corporation (2025). 2025-2026 Winter Reliability Assessment: Rising Demand, Evolving Resources Continue to Challenge Winter Grid Reliability. -- https://www.nerc.com/newsroom/2025-winter-reliability-assessment

* [27] Potomac Economics (Jun 2025). 2024 State of the Market Report for the ERCOT Electricity Markets. -- https://www.potomaceconomics.com/wp-content/uploads/2025/06/2024-State-of-the-Market-Report.pdf

* [28] U.S. Energy Information Administration (Aug. 3, 2026). Hourly peak load in ERCOT set a new record, exceeding 91 GW on July 22. -- https://www.eia.gov/todayinenergy/detail.php?id=67906

* [29] U.S. Energy Information Administration (Oct. 15, 2026). PJM, ERCOT, and SWPP all set peak load records this summer. -- https://www.eia.gov/todayinenergy/detail.php?id=68305

* [30] ERCOT (June 18, 2026). PUCT Approves ERCOT's Batch Zero Process for Connecting Large Electricity Users While Protecting System Reliability for Texans. -- https://www.ercot.com/news/release/06182026-puct-approves-ercots